



P.O. Box 1058 • 370 South Athol Rd.
Athol, Massachusetts 01331
Phone: (978) 249-7924
Fax: (978) 249-3072

SECTION _____
ALUMINUM DUAL LEAF GATES

PART 1 GENERAL

1.01 SCOPE OF WORK

- A. The CONTRACTOR shall furnish all labor, materials, equipment and incidentals required to install, ready for operation and field test aluminum gates and appurtenances as shown on the Contract Drawings and as specified herein.
- B. The gates and appurtenances shall be supplied in accordance with the latest edition of AWWA C562 Standard for Fabricated Aluminum Slide Gates as modified herein.

1.02 SUBMITTALS

- A. Provide the following information to confirm compliance with the specification in addition to the submittal requirements specified in Section _____.
 - 1. Complete description of all materials including the material thickness of all structural components of the frame and slide.
 - 2. Installation drawings showing all details of construction, details required for installation, dimensions and anchor bolt locations.
 - 3. Maximum bending stress and deflection of the slide under the maximum design head.
 - 4. The location of the company headquarters and the location of the principle manufacturing facility. Provide the name of the company that manufactures the equipment if the supplier utilizes an outside source.

1.03 QUALITY ASSURANCE

- A. Qualifications
 - 1. All of the equipment specified under this Section shall be furnished by a single manufacturer with a minimum of 20 years experience designing and manufacturing water control gates. The manufacturer shall have manufactured water control gates for a minimum of 100 projects.
 - 2. The specification is based on the 800 Series Aluminum Gate as manufactured by Whipps, Inc. of Athol, Massachusetts.

PART 2 EQUIPMENT

2.01 GENERAL

- A. Gates shall be as specified herein and have the characteristics and dimensions shown on the Contract Drawings.
- B. Dual Leaf Slide Gates shall be provided where shown on the Plans. Depending on design, one gate slide shall lift or lower the mating slide as required. Special neoprene and UHMW polyethylene seats/seals shall be used between each slide (leaf). Each slide gate shall be

designed to travel in its own guide slot. Leakage shall not exceed 0.20 gpm/ft of wetted seal perimeter in seating head and unseating head conditions for dual leaf slide gates.

- C. The gate shall utilize self-adjusting seals. Due to the difficulty of accessing gates when they are in service, gates that utilize adjustable wedges, wedging devices or pressure pads are not acceptable.
- D. All structural components of the frame and slide shall be fabricated of aluminum having a minimum thickness of 1/4-inch and shall have adequate strength to prevent distortion during normal handling, during installation and while in service.
- E. Slide gate frames shall be shipped fully assembled with the invert member welded to the side frames and the slide installed in the frame unless the overall width of the slide gate exceeds 96 inches or the overall height of the slide gate exceed 25 feet.
- F. All welds shall be performed by welders with AWS D1.6 certification.
- G. Finish: Mill finish on extruded aluminum shapes. Welds shall be cleaned to remove weld burn and scale.
- H. Materials:

Components

Frame Guides, Yoke and Invert Member
 Slide and Stiffeners
 Stem
 Anchor Studs, Fasteners and Nuts
 Invert Seal (Upward Opening Gates Only)
 Seat/Seal and Facing

Lift Nuts
 Pedestal
 Operator Housing

Materials

6061-T6 Aluminum
 6061-T6 Aluminum
 Stainless Steel, Type 304, ASTM A276
 Stainless Steel, Type 316, ASTM A276
 Neoprene ASTM D-2000 or EPDM
 Ultra-High Molecular Weight Polyethylene
 ASTM D4020
 Bronze ASTM B584
 Stainless Steel, ASTM A-276 Type 304L
 Cast aluminum or ductile iron

2.02 FRAME

- A. The frame assembly, including the guide members, invert member and yoke members, shall be constructed of extruded aluminum with a minimum thickness of 1/4-inch.
 - 1. Frame design shall allow for embedded mounting, mounting directly to a wall with stainless steel anchor bolts and grout or mounting to a wall thimble with stainless steel mounting studs and a mastic gasket material. Mounting style shall be as shown on the Contract Drawings.
 - 2. The frame guides shall be comprised of aluminum extrusions and have a minimum combined weight of 6 pounds per foot.
 - 3. The frame shall extend to accommodate the entire height of the slide when the slide is in the fully opened position on upward opening gates or downward opening weir gates.
 - 4. On self-contained gates, a yoke shall be provided across the top of the frame. The yoke shall be formed by two structural members affixed to the top of the side frame members to provide a one-piece rigid assembly. The yoke shall be designed to allow removal of the slide.
 - 5. A rigid aluminum invert member shall be provided across the bottom of the opening. The invert member shall be of the flushbottom type on upward opening gates.
 - 6. A rigid aluminum top seal member shall be provided across the top of the opening on gates designed to cover submerged openings.
 - 7. A rigid aluminum member shall be provided across the invert of the opening on downward opening weir gates.

2.03 SLIDE

- A. The slide and reinforcing stiffeners shall be constructed of aluminum plate. All structural components shall have a minimum thickness of 1/4-inch.
 - 1. The slide shall not deflect more than 1/360 of the span or 1/16 inch, whichever is smaller, under the maximum design head.
 - 2. Reinforcing stiffeners shall be welded to the slide and mounted horizontally. Vertical stiffeners shall be welded on the outside of the horizontal stiffeners for additional reinforcement.
 - 3. The stem connector shall be constructed of two angles or plates. The stem connector shall be welded to the slide. A minimum of two bolts shall connect the stem to the stem connector.

2.04 SEALS

- A. All gates shall be provided with a self-adjusting seal system to restrict leakage in accordance with the requirements listed in this specification.
 - 1. All gates shall be equipped with UHMW polyethylene seat/seals to restrict leakage and to prevent metal to metal contact between the frame and slide.
 - 2. The seat/seals shall extend to accommodate the 1-1/2 x the height of the slide when the slide is in the fully closed or fully opened position.
 - 3. All upward opening gates shall be provided with a resilient seal to seal the bottom portion of the gate. The seal shall be attached to the invert member or the bottom of the slide and it shall be held in place with stainless steel attachment hardware.
 - 4. All downward opening weir gates shall be provided with UHMW polyethylene seat/seals across the invert member.
 - 5. The seal system shall be durable and shall be designed to accommodate high velocities and frequent cycling without loosening or suffering damage. Seals that are held in place with adhesives are not acceptable.
 - 6. The seals shall be mounted so as not to obstruct the water way opening.
 - 7. The horizontal seal between the two slides will be a neoprene or EPDM bulb type seal.

2.05 STEM

- A. A threaded operating stem shall be utilized to connect the operating mechanism to the slide. On rising stem gates, the threaded portion shall engage the operating nut in the manual operator or motor actuator. On non-rising stem gates, the threaded portion shall engage the nut on the slide.
 - 1. The threaded portion of the stem shall have a minimum outside diameter of 1-1/2 inches. Stem extension pipes are not acceptable.
 - 2. The stem shall be constructed of solid stainless steel bar for the entire length, the metal having a tensile strength of not less than 75,000 psi.
 - 3. The stem shall be threaded to allow full travel of the slide unless the travel distance is otherwise shown on the Contract Drawings.
 - 4. Maximum L/R ratio for the unsupported part of the stem shall not exceed 200.
 - 5. In compression, the stem shall be designed for a critical buckling load caused by a 40 lb effort on the crank or handwheel with a safety factor of 2, using the Euler column formula.
 - 6. The stem shall be designed to withstand the tension load caused by the application of a 40 lb effort on the crank or handwheel without exceeding 1/5 of the ultimate tensile strength of the stem material.
 - 7. The threaded portion of the stem shall have machine rolled threads of the full Acme type with a 16 microinch finish or better. Stub threads are not acceptable.
 - 8. Stems of more than one section shall be joined by stainless steel or bronze couplings. The coupling shall be bolted to the stems.

9. Stems, on manually operated gates, shall be provided with adjustable stop collars to prevent over closing of the slide.

2.06 STEM GUIDES

- A. Stem guide shall be provided when necessary to ensure that the maximum L/R ratio for the unsupported part of the stem is 200 or less.
 1. Stem guide brackets shall be fabricated of stainless steel and shall be outfitted with UHMW or bronze bushings.
 2. Adjustable in two directions.

2.07 MANUAL OPERATORS

- A. Unless otherwise shown on the Drawings, gates shall be operated by a manual handwheel or a manual crank-operated gearbox. The operator shall be mounted on the yoke of self contained gates or on the pedestal of non-self contained gates.
 1. The gate manufacturer shall select the proper gear ratio to ensure that the gate can be operated with no more than a 40 lb effort when the gate is in the closed position and experiencing the maximum operating head.
 2. An arrow with the word "OPEN" shall be permanently attached or cast onto the operator to indicate the direction or rotation to open the gate.
 3. Handwheel operators shall be fully enclosed and shall have a cast aluminum housing.
 - a. Handwheel operators shall be provided with a threaded cast bronze lift nut to engage the operating stem.
 - b. Handwheel operators shall be equipped with roller bearings above and below the operating nut.
 - c. Positive mechanical seals shall be provided above and below the operating nut to exclude moisture and dirt and prevent leakage of lubricant out of the hoist.
 - d. The handwheel shall be removable and shall have a minimum diameter of 15 inches.
 4. Crank-operated gearboxes shall be fully enclosed and shall have a cast aluminum or ductile iron housing.
 - a. Gearboxes shall have either single or double gear reduction depending upon the lifting capacity required.
 - b. Gearboxes shall be provided with a threaded cast bronze lift nut to engage the operating stem.
 - c. Bearings shall be provided above and below the flange on the operating nut to support both opening and closing thrusts.
 - d. Gears shall be steel with machined cut teeth designed for smooth operation.
 - e. The pinion shaft shall be stainless steel and shall be supported on ball or tapered roller bearings.
 - f. Positive mechanical seals shall be provided on the operating nut and the pinion shafts to exclude moisture and dirt and prevent leakage of lubricant out of the hoist.
 - g. The crank shall be cast aluminum or cast iron with a revolving nylon grip.
 - h. The crank shall be removable.
 5. All gates having widths in excess of 72 inches and widths greater than twice their height shall be provided with two gearboxes connected by an interconnecting shaft for simultaneous operation.
 - a. Interconnecting shafting shall be constructed of aluminum or stainless steel.
 - b. Flexible couplings shall be provided at each end of the interconnecting shaft. Couplings shall be stainless steel or non-metallic.
 - c. One crank shall be provided to mount on the pinion shaft of one of the gearboxes.

6. An extended operator system utilizing chain and sprockets shall be furnished by the manufacturer when the centerline of the crank or handwheel, on a non-gear operator, is located over 48-in above the operating floor. Chain wheels are not acceptable.
 - a. A removable stainless steel or aluminum cover shall be provided to enclose chain and sprockets.
 - b. The extended operator system shall lower the centerline of the pinion shaft to 36-in above the operating floor.
 - c. A handwheel may be utilized in conjunction with a gearbox in lieu of the extended operator system if the centerline of the pinion shaft is 60-in or less above the operating floor.
7. Pedestals shall be constructed of stainless steel. Aluminum pedestals are not acceptable.
 - a. The pedestal height shall be such that the handwheel or pinion shaft on the crank-operated gearbox is located approximately 36-in above the operating floor.
 - b. Wall brackets shall be used to support floor stands where shown on the Drawings and shall be constructed of stainless steel.
 - c. Wall brackets shall be reinforced to withstand in compression at least two times the rated output of the operator with a 40 lb effort on the crank or handwheel.
 - d. The design and detail of the brackets and anchor bolts shall be provided by the gate manufacturer and shall be approved by the ENGINEER. The gate manufacturer shall supply the bracket, anchor bolts and accessories as part of the gate assembly.
8. Operators shall be equipped with fracture-resistant clear butyrate or lexan plastic stem covers.
 - a. The top of the stem cover shall be closed.
 - b. The bottom end of the stem cover shall be mounted in a housing or adapter for easy field mounting.
 - c. Stem covers shall be complete with indicator markings to indicate gate position.
9. When shown on the Contract Drawings, provide 2 inch square nut, mounted in a floor box, with a non-rising stem.
 - a. The square nut shall be constructed of bronze.
 - b. The floor box shall be constructed of stainless steel or cast iron and shall be set in the concrete floor above the gate as shown.
 - c. Provide one aluminum or stainless steel T-handle wrench for operation.

2.08 ELECTRIC MOTOR ACTUATORS

A. See Section _____.

2.09 ANCHOR BOLTS

- A. Anchor bolts shall be provided by the gate manufacturer for mounting the gates and appurtenances.
1. Quantity and location shall be determined by the gate manufacturer.
 2. If epoxy type anchor bolts are provided, the gate manufacturer shall provide the studs and nuts.
 3. Anchor bolts shall have a minimum diameter of 1/2-inch.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Installation of the gates and appurtenances shall be done in a workmanlike manner. It shall be the responsibility of the CONTRACTOR to handle, store and install the equipment specified in this Section in strict accordance with the manufacturer's recommendations.
- B. The CONTRACTOR shall review the installation drawings and installation instruction prior to installing the gates.
- C. The gate assemblies shall be installed in a true vertical plane, square and plumb.
- D. The CONTRACTOR shall fill the void in between the gate frame and the wall with non-shrink grout as shown on the installation drawing and in accordance with the manufacturer's recommendations.
- E. The CONTRACTOR shall add a mastic gasket between the gate frame and wall thimble (when applicable) in accordance with the manufacturer's recommendations.

3.02 FIELD TESTING

- A. After installation, all gates shall be field tested in the presence of the ENGINEER and OWNER to ensure that all items of equipment are in full compliance with this Section. Each gate shall be cycled to confirm that they operate without binding, scraping, or distorting. The effort to open and close manual operators shall be measured, and shall not exceed the maximum operating effort specified above. Electric motor actuators shall function smoothly and without interruption. Each gate shall be water tested by the CONTRACTOR, at the discretion of the ENGINEER and OWNER, to confirm that leakage does not exceed the specified allowable leakage.

END OF SECTION